

McKnight Crossings Lighting Project – Open Items

April 3, 2023

Chad Killion, Operations Manager
Elite Technology Solutions
1250 Jungerman Road
St Peters, MO 63376
636-939-4474 : Office
636-577-4066 : Cell
www.elite1988.com

Chad,

It is the start of April and I wanted to follow-up on a few open items from our job.

1. **Replacement of temporary equipment** – Currently McKnight is using several pieces of temporary equipment until Elite receives the final new items.
 - a. 192.168.2.19 temporary Crestron CP3 control processor – do you have an estimate on when the new CP4 should be received?
 - b. 192.168.2.22/23 – temporary control processors
 - i. When will the new units be received?
 - ii. Current temporary units are loose in cabinet (see **Exhibit B**) but expect that permanent units will be installed in network rack in same room on wall (see **Exhibit A**).
2. **Electrical issue** – On March 6, 2023 we had Scott from Branham Electric review an issue with the electrical wiring installed as part of Elite's lighting project. Below is our Facilities Manager, Tom Hunsaker's description of the issue (from an earlier email):

*I came across an incorrectly wired circuit that I believe was wired when the new lights in the auditorium were installed [Panel A, breaker #22]. **When the circuit is turned "off", the RED spotlight comes "on" when the circuit should be DEAD.** Also, we never received a schematic of the circuits re-wired by Elite, and I cannot work on any of our old circuits in there without knowing what they tapped into.*

On Monday, March 6, 2023 at 02:31:41 PM CST, Tom Hunsaker <thunsaker@mcknightcrossings.org> wrote:

Bret==

Met with Scott this morning from Branham Electric. He did not put it in and said he would have to talk to his guy that did the work. He said the problem was with the low voltage circuitry and would have his guy come out in 10 days or so. I told him we need some kind of schematic or drawing showing what they hooked up to what. Scott told me they dropped wire into Panel "C", but Panel "A" is affected at Breaker #22 with the Red spotlight, so we will wait to talk to the guy that actually installed it. Will keep you posted.

Tom

McKnight Crossings Lighting Project – Open Items

April 3, 2023

Exhibit A

Below notes the rack where new equipment is intended to be mounted



Exhibit B

Below notes location of temporary equipment

