

# Inspection and Testing Certificate

Presented To

McKnight Crossings Church of Christ

For

McKnight Crossings Church of Christ - 21472FAIN03101 building

2515 South McKnight Rd.  
St. Louis, Missouri 63124  
United States

This site has been inspected and tested in compliance with applicable standards.

Completed

Monday, August 29, 2022

Test Session :29 Aug 2022 14:33

ACCEPTED BY

McKnight Crossings Church of Christ  
2515 South McKnight Rd.  
St. Louis, Missouri 63124  
United States

TESTED BY

John Turin  
Tech Electronics of St. Louis  
6437 Manchester Ave  
St. Louis, MO  
United States



# Inspection Summary

## Building Information

PROPERTY	McKnight Crossings Church of Christ - 21472FAIN03101 building	CONTACT
ADDRESS	2515 South McKnight Rd.	PHONE
CITY/STATE/ZIP	St. Louis, Missouri 63124	MOBILE
COUNTRY	United States	EMAIL

## Inspector Information

COMPANY	Tech Electronics of St. Louis	CONTACT	John Turin
ADDRESS	6437 Manchester Ave St. Louis, MO	LICENSE NUMBER	
COUNTRY	United States	PHONE	
		EMAIL	john.turin@techelectronics.com

## Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	29	29(100%)	29(100%)	0(0%)
Emergency Control Equipment	7	5(71%)	5(71%)	0(0%)
Emergency Lighting and Power	1	0(0%)	0(0%)	0(0%)
Fire Control Panel	1	1(100%)	1(100%)	0(0%)
Initiating Device	19	17(89%)	17(89%)	0(0%)
Power Supplies	4	4(100%)	4(100%)	0(0%)
Supervising Station Transmitting Equipment	2	2(100%)	2(100%)	0(0%)
Ventilation and Cooking Equipment	1	0(0%)	0(0%)	0(0%)

## Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Monday, August 29, 2022

ACCEPTED BY	08/29/2022	TESTED BY	08/29/2022
	Building Representative		John Turin
			Technician

## System Details

### Control Units

MANUFACTURER	Notifier	DESCRIPTION	FACP is located in main office.
MODEL	AFP-200	S/W VERSION	2.43
SERIAL NUMBER		LAST UPDATE	
INSTALL DATE		S/W LOCATION	

### Secondary Power

TYPE	Battery - Sealed Lead-acid	DESCRIPTION	FACP is located in main office.
NOMINAL VOLTAGE	12	LOAD VOLTAGE	13.11
AMP HOURS	12	STANDBY HOURS	24
ALARM MINUTES	5	BATTERY LOCATION	
CHARGER VOLTAGE	13.39		
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	FACP is located in main office.
NOMINAL VOLTAGE	12	LOAD VOLTAGE	13.11
AMP HOURS	12	STANDBY HOURS	24
ALARM MINUTES	5	BATTERY LOCATION	
CHARGER VOLTAGE	13.43		
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	411UDAC is located in Lobby.
NOMINAL VOLTAGE	12	LOAD VOLTAGE	12.89
AMP HOURS	7	STANDBY HOURS	24
ALARM MINUTES	5	BATTERY LOCATION	
CHARGER VOLTAGE	13.11		
TYPE	Battery - Sealed Lead-acid	DESCRIPTION	NAPCO is located in Lobby A/C.
NOMINAL VOLTAGE	12	LOAD VOLTAGE	12.79
AMP HOURS	7	STANDBY HOURS	24
ALARM MINUTES	5	BATTERY LOCATION	
CHARGER VOLTAGE	13.12		

### Monitoring Information

UDAC-1	411UDAC is located in Lobby.		
TYPE	Digital Alarm Communicator Transmitter	INSTALL DATE	
MANUFACTURER	FireWatch	TEST START	08/29/2022
MODEL	411UDAC	TEST COMPLETE	08/29/2022
SERIAL NUMBER		Time to Transmit to Supervising Station	
MONITORING ORGANIZATION	Center Point	ALARM SIGNAL	39_sec
MONITORING ORGANIZATION PHONE		ALARM RESTORE	
MONITORING ORGANIZATION EMAIL		TROUBLE SIGNAL	41_sec
MONITORING ORGANIZATION ACCOUNT NUMBER		TROUBLE RESTORE	
MONITORING PHONE LINE 1		SUPERVISORY SIGNAL	
MONITORING PHONE LINE 2		SUPERVISORY RESTORE	
MONITORING RETRANSMISSION ENTITY			

NAPCO-2		NAPCO is located in Lobby A/C.	
TYPE	Digital Alarm Communicator Transmitter	INSTALL DATE	
MANUFACTURER	NAPCO/STARLINK	TEST START	08/29/2022
MODEL	SLE-LTEVI-CFBPS	TEST COMPLETE	08/29/2022
SERIAL NUMBER		Time to Transmit to Supervising Station	
MONITORING ORGANIZATION		ALARM SIGNAL	
MONITORING ORGANIZATION PHONE		ALARM RESTORE	
MONITORING ORGANIZATION EMAIL		TROUBLE SIGNAL	
MONITORING ORGANIZATION ACCOUNT NUMBER		TROUBLE RESTORE	
MONITORING PHONE LINE 1		SUPERVISORY SIGNAL	
MONITORING PHONE LINE 2		SUPERVISORY RESTORE	
MONITORING RETRANSMISSION ENTITY			

# Testing Details

## Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Horn/Strobe	HRNSTRB-01	2ND FL	Manual	8/29/2022 2:35:31 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Horn/Strobe	HRNSTRB-02	2ND FL	Manual	8/29/2022 2:35:33 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Horn/Strobe	HRNSTRB-03	2ND FL	Manual	8/29/2022 2:35:34 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Horn/Strobe	HRNSTRB-04	1ST FL	Manual	8/29/2022 2:35:35 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Horn/Strobe	HRNSTRB-05	1ST FL	Manual	8/29/2022 2:35:37 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Horn/Strobe	HRNSTRB-06	1ST FL	Manual	8/29/2022 2:35:38 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Horn/Strobe	HRNSTRB-07	1ST FL	Manual	8/29/2022 2:35:40 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Horn/Strobe	HRNSTRB-08	1ST FL	Manual	8/29/2022 2:35:41 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Horn/Strobe	HRNSTRB-09	1ST FL	Manual	8/29/2022 2:35:42 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Horn/Strobe	HRNSTRB-10	1ST FL	Manual	8/29/2022 2:35:44 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Horn/Strobe	HRNSTRB-11	1ST FL	Manual	8/29/2022 2:35:45 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Horn/Strobe	HRNSTRB-12	1ST FL	Manual	8/29/2022 2:35:46 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Horn/Strobe	HRNSTRB-13	1ST FL	Manual	8/29/2022 2:35:48 PM
		Manufacturer	Gentex	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Horn/Strobe	HRNSTRB-14	1ST FL	Manual	8/29/2022 2:35:49 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Horn/Strobe	HRNSTRB-15	1ST FL	Manual	8/29/2022 2:35:51 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Horn/Strobe	HRNSTRB-16	1ST FL	Manual	8/29/2022 2:35:52 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Horn/Strobe	HRNSTRB-17	1ST FL	Manual	8/29/2022 2:35:54 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Strobe	STRB-01	1ST FL	Manual	8/29/2022 2:36:38 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Strobe	STRB-02	1ST FL	Manual	8/29/2022 2:36:40 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Strobe	STRB-03	1ST FL	Manual	8/29/2022 2:36:42 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Strobe	STRB-04	1ST FL	Manual	8/29/2022 2:36:43 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Strobe	STRB-05	1ST FL	Manual	8/29/2022 2:36:45 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Strobe	STRB-06	1ST FL	Manual	8/29/2022 2:36:46 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Strobe	STRB-07	1ST FL	Manual	8/29/2022 2:36:48 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Strobe	STRB-08	1ST FL	Manual	8/29/2022 2:36:50 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Strobe	STRB-09	1ST FL	Manual	8/29/2022 2:36:52 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Strobe	STRB-10	1ST FL	Manual	8/29/2022 2:36:54 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Strobe	STRB-11	1ST FL	Manual	8/29/2022 2:36:56 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Strobe	STRB-12	1ST FL	Manual	8/29/2022 2:36:58 PM
		Manufacturer	Gentex	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

### Emergency Control Equipment

#### Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Door Control Relay	M03	DOOR HOLDERS	Manual	8/29/2022 2:36:01 PM
		Manufacturer	Notifier	
		Model	FRM-1	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
HVAC Shutdown	M10	RTU-4 CANTEEN IN GYM	Manual	8/29/2022 2:36:05 PM
		Manufacturer	Notifier	
		Model	FRM-1	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Door Control Relay	M11	AUD DR PANIC RELEASE	Manual	8/29/2022 2:36:07 PM
		Manufacturer	Notifier	
		Model	FRM-1	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
HVAC Shutdown	M8	1ST FL MACHINE RM-ELEVATOR	Manual	8/29/2022 2:36:33 PM
		Manufacturer	Notifier	
		Model	FRM-1	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
HVAC Shutdown	M9	RTU-3 CLASS RM 112B IN GYM	Manual	8/29/2022 2:36:35 PM
		Manufacturer	Notifier	
		Model	FRM-1	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

#### Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Elevator Recall - Primary	M60	PRIMARY	Manual	8/29/2022 2:43:46 PM
	Comment:	Elevator company not on site at time of inspection.		
		Manufacturer	Notifier	
		Model	FRM-1	
Elevator Recall - Alternate	M61	ALTERNATE	Manual	8/29/2022 2:43:46 PM
	Comment:	Elevator company not on site at time of inspection.		
		Manufacturer	Notifier	
		Model	FRM-1	

### Emergency Lighting and Power

#### Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Egress Elevator Status Indicator	M62	FIRE HAT	Manual	8/29/2022 2:43:46 PM
	Comment:	Elevator company not on site at time of inspection.		
		Manufacturer	Notifier	
		Model	FRM-1	

## Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Panel	FACP	FACP is located in main office.	Manual	8/29/2022 2:38:59 PM
		Manufacturer	Notifier	
		Model	AFP-200	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Signal	39_sec	
		Software Version	2.43	
		Trouble Signal	41_sec	

## Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector	D01	LOBBY TO CHAPEL	Manual	8/29/2022 2:34:24 PM
		Manufacturer	System Sensor	
		Model	FSP-851	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector	D02	LOBBY TO CHAPEL	Manual	8/29/2022 2:34:26 PM
		Manufacturer	System Sensor	
		Model	FSP-851	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector	D03	1ST FL ELEVATOR LOBBY	Manual	8/29/2022 2:34:29 PM
		Manufacturer	System Sensor	
		Model	FSP-851	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector	D04	2ND FL ELEVATOR LOBBY	Manual	8/29/2022 2:34:31 PM
		Manufacturer	System Sensor	
		Model	FSP-851	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector	D05	3RD FL ELEVATOR LOBBY	Manual	8/29/2022 2:34:34 PM
		Manufacturer	System Sensor	
		Model	FSP-851	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector	D06	4TH FL ELEVATOR LOBBY	Manual	8/29/2022 2:34:36 PM
		Manufacturer	System Sensor	
		Model	FSP-851	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector	D07	1ST FL MACHINE RM-ELEVATOR	Manual	8/29/2022 2:34:39 PM
		Manufacturer	System Sensor	
		Model	FSP-851	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector	D08	RTU-3 CLASS RM 112B IN GYM	Manual	8/29/2022 2:34:43 PM
		Manufacturer	System Sensor	
		Model	FSD-751P	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector	D09	RTU-4 CANTEEN IN GYM	Manual	8/29/2022 2:34:45 PM
		Manufacturer	System Sensor	
		Model	FSD-751P	



EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector	D10	RTU-2 KITCHEN	Manual	8/29/2022 2:34:48 PM
		Manufacturer	System Sensor	
		Model	FSD-751P	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector	D13	LOBBY TO CHAPEL	Manual	8/29/2022 2:35:16 PM
		Manufacturer	System Sensor	
		Model	FSP-851	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector	D14	CHAPEL TO LOBBY	Manual	8/29/2022 2:35:18 PM
		Manufacturer	System Sensor	
		Model	FSP-851	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector	D15	CHAPEL TO LOBBY	Manual	8/29/2022 2:35:20 PM
		Manufacturer	System Sensor	
		Model	FSP-851	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Smoke Detector	D16	CHAPEL TO LOBBY	Manual	8/29/2022 2:35:22 PM
		Manufacturer	System Sensor	
		Model	FSP-851	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	M01	LOBBY	Manual	8/29/2022 2:35:56 PM
		Manufacturer	Notifier	
		Model	NBG-12LX	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	M02	FELLOWSHIP COMMON	Manual	8/29/2022 2:35:58 PM
		Manufacturer	Notifier	
		Model	NBG-12LX	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
Manual Pull Station	M04	PRESCHOOL N. STAIRS	Manual	8/29/2022 2:36:02 PM
		Manufacturer	Notifier	
		Model	NBG-12LX	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector	D11	PIT-ELEVATOR	Manual	8/29/2022 2:43:46 PM
	Comment:	Elevator company not on site at time of inspection.		
		Manufacturer	System Sensor	
		Model	FSP-851	
Smoke Detector	D12	SHAFT-ELEVATOR	Manual	8/29/2022 2:43:46 PM
	Comment:	Elevator company not on site at time of inspection.		
		Manufacturer	System Sensor	
		Model	FSP-851	

Power Supplies

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
----------------	---------	-------------	--------	-----------

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Battery - Sealed Lead-acid	DBATT-01	411UDAC is located in Lobby.	Manual	8/29/2022 2:37:44 PM
		Manufacturer	PowerSonic	
		Model	PS-1270	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Minutes	5	
		Amp Hours	7	
		Charger Voltage	13.11	
		Load Voltage	12.89	
		Nominal Voltage	12	
		Stand By Hours	24	
Battery - Sealed Lead-acid	DBATT-02	NAPCO is located in Lobby A/C.	Manual	8/29/2022 2:38:19 PM
		Manufacturer	PowerSonic	
		Model	PS-1270	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Minutes	5	
		Amp Hours	7	
		Charger Voltage	13.12	
		Load Voltage	12.79	
		Nominal Voltage	12	
		Stand By Hours	24	
Battery - Sealed Lead-acid	FACPBATT-01	FACP is located in main office.	Manual	8/29/2022 2:39:39 PM
		Manufacturer	Duracell	
		Model	DURA12-12F2	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Minutes	5	
		Amp Hours	12	
		Charger Voltage	13.43	
		Load Voltage	13.11	
		Nominal Voltage	12	
		Stand By Hours	24	
Battery - Sealed Lead-acid	FACPBATT-02	FACP is located in main office.	Manual	8/29/2022 2:40:21 PM
		Manufacturer	Duracell	
		Model	DURA12-12F2	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Alarm Minutes	5	
		Amp Hours	12	
		Charger Voltage	13.39	
		Load Voltage	13.11	
		Nominal Voltage	12	
		Stand By Hours	24	

**Supervising Station Transmitting Equipment**

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Digital Alarm Communicator Transmitter	NAPCO-2	NAPCO is located in Lobby A/C.	Manual	8/29/2022 2:42:21 PM
		Manufacturer	NAPCO/STARLINK	
		Model	SLE-LTEVI-CFBPS	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		In Service Date/time for dialer	2022-08-15T20:00:00Z	
		Out of Service Date/Time	2022-08-15T13:00:00Z	
Digital Alarm Communicator Transmitter	UDAC-1	411UDAC is located in Lobby.	Manual	8/29/2022 2:43:40 PM
		Manufacturer	FireWatch	
		Model	411UDAC	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Alarm Signal	39_sec	
		In Service Date/time for dialer	2022-08-15T20:00:00Z	
		Monitoring Organization	Center Point	
		Out of Service Date/Time	2022-08-15T13:00:00Z	
		Trouble Signal	41_sec	

**Ventilation and Cooking Equipment**

Skipped

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Range Hood	M20	KITCHEN HOOD	Manual	8/29/2022 2:43:46 PM
	Comment:	Tested by other.		
		Manufacturer	Notifier	
		Model	FMM-1	

## Device/Equipment Details

### Alarm Notification Appliance

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Horn/Strobe					
HRNSTRB-01	2ND FL	Gentex			
HRNSTRB-02	2ND FL	Gentex			
HRNSTRB-03	2ND FL	Gentex			
HRNSTRB-04	1ST FL	Gentex			
HRNSTRB-05	1ST FL	Gentex			
HRNSTRB-06	1ST FL	Gentex			
HRNSTRB-07	1ST FL	Gentex			
HRNSTRB-08	1ST FL	Gentex			
HRNSTRB-09	1ST FL	Gentex			
HRNSTRB-10	1ST FL	Gentex			
HRNSTRB-11	1ST FL	Gentex			
HRNSTRB-12	1ST FL	Gentex			
HRNSTRB-13	1ST FL	Gentex			
HRNSTRB-14	1ST FL	Gentex			
HRNSTRB-15	1ST FL	Gentex			
HRNSTRB-16	1ST FL	Gentex			
HRNSTRB-17	1ST FL	Gentex			
Strobe					
STRB-01	1ST FL	Gentex			
STRB-02	1ST FL	Gentex			
STRB-03	1ST FL	Gentex			
STRB-04	1ST FL	Gentex			
STRB-05	1ST FL	Gentex			
STRB-06	1ST FL	Gentex			
STRB-07	1ST FL	Gentex			
STRB-08	1ST FL	Gentex			
STRB-09	1ST FL	Gentex			
STRB-10	1ST FL	Gentex			
STRB-11	1ST FL	Gentex			
STRB-12	1ST FL	Gentex			

### Emergency Control Equipment

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Door Control Relay					
M03	DOOR HOLDERS	Notifier	FRM-1		
M11	AUD DR PANIC RELEASE	Notifier	FRM-1		
Elevator Recall - Primary					
M60	PRIMARY	Notifier	FRM-1		
Elevator Recall - Alternate					
M61	ALTERNATE	Notifier	FRM-1		
HVAC Shutdown					
M8	1ST FL MACHINE RM- ELEVATOR	Notifier	FRM-1		
M9	RTU-3 CLASS RM 112B IN GYM	Notifier	FRM-1		
M10	RTU-4 CANTEEN IN GYM	Notifier	FRM-1		

### Emergency Lighting and Power

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Egress Elevator Status Indicator					

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
M62	FIRE HAT	Notifier	FRM-1		

### Fire Control Panel

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Fire Alarm Panel					
FACP	FACP is located in main office.	Notifier	AFP-200		

### Initiating Device

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Smoke Detector					
D01	LOBBY TO CHAPEL	System Sensor	FSP-851		
D02	LOBBY TO CHAPEL	System Sensor	FSP-851		
D03	1ST FL ELEVATOR LOBBY	System Sensor	FSP-851		
D04	2ND FL ELEVATOR LOBBY	System Sensor	FSP-851		
D05	3RD FL ELEVATOR LOBBY	System Sensor	FSP-851		
D06	4TH FL ELEVATOR LOBBY	System Sensor	FSP-851		
D07	1ST FL MACHINE RM- ELEVATOR	System Sensor	FSP-851		
D08	RTU-3 CLASS RM 112B IN GYM	System Sensor	FSD-751P		
D09	RTU-4 CANTEEN IN GYM	System Sensor	FSD-751P		
D10	RTU-2 KITCHEN	System Sensor	FSD-751P		
D11	PIT-ELEVATOR	System Sensor	FSP-851		
D12	SHAFT-ELEVATOR	System Sensor	FSP-851		
D13	LOBBY TO CHAPEL	System Sensor	FSP-851		
D14	CHAPEL TO LOBBY	System Sensor	FSP-851		
D15	CHAPEL TO LOBBY	System Sensor	FSP-851		
D16	CHAPEL TO LOBBY	System Sensor	FSP-851		

### Manual Pull Station

M01	LOBBY	Notifier	NBG-12LX		
M02	FELLOWSHIP COMMON	Notifier	NBG-12LX		
M04	PRESCHOOL N. STAIRS	Notifier	NBG-12LX		

### Power Supplies

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Battery - Sealed Lead-acid					
FACPBATT-01	FACP is located in main office.	Duracell	DURA12-12F2		09/24/2020
FACPBATT-02	FACP is located in main office.	Duracell	DURA12-12F2		09/24/2020
DBATT-01	411UDAC is located in Lobby.	PowerSonic	PS-1270		07/07/2020
DBATT-02	NAPCO is located in Lobby A/C.	PowerSonic	PS-1270		07/28/2018

### Supervising Station Transmitting Equipment

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Digital Alarm Communicator Transmitter					
UDAC-1	411UDAC is located in Lobby.	FireWatch	411UDAC		
NAPCO-2	NAPCO is located in Lobby A/C.	NAPCO/STARLINK	SLE-LTEVI-CFBPS		

### Ventilation and Cooking Equipment

ADDRESS	DESCRIPTION	MANUFACTURER	MODEL	SERIAL	INSTALL DATE
Range Hood					
M20	KITCHEN HOOD	Notifier	FMM-1		